

**State Bar Court of California
Los Angeles Courtroom Teleconference and Audio Systems RFP**

Questions received to date September 8, 2006

- 3. Will we need to work around court events or will there be a certain block of time when all of the courtrooms are dark for the installations to take place?**

It depends on how many days the vendor expects an installation to take place. Assuming that an installation will only take one or two days per courtroom, we may be able to block out consecutive one or two-day periods and relocate some events to courtrooms that are not being worked on.

- 4. How much of the carpeting would have to be lifted and reattached (glued down) placed for access to the wiring trough for any additional or new wiring?**

The wiring trough for courtroom A is located along the corridor on the side of courtroom A. A panel of approximately 7 ft. x 2 ft. would have to be cut in the carpet in front of the outer entrance to courtroom A to obtain full access to the trough to fish wire into the courtroom. If any new wiring is to be installed in courtroom B, the vendor could use the panel in front of courtroom A for that installation. If there is to be any new wiring installed for courtrooms C, D and E, each courtroom would require an approximately 2 ft. x 2 ft. opening in the hallway carpeting to fish wire into those courtrooms.