

**State Bar Court of California
Los Angeles Courtroom Teleconference and Audio Systems RFP**

Question received to date August 29, 2006

1. Will the State Bar / State Bar Court waive the requirement that “Attendance is mandatory for all vendors intending to submit a proposal”?

The requirement has been waived due to the small number of interested vendors. Should additional vendors become known to us and interested in bidding on the proposal, another pre-bid conference may be offered before September 13, 2006.

2. How does the wiring, for the overhead speakers in Courtroom A, run to the mixer? Where do the conduits runs originate and terminate?

To answer this question, a meeting was arranged with a representative of the building’s electrical contractor on Wednesday, August 30, 2006. The electrician opened one of the wiring closets for viewing. For those not present to observe and listen to the electrician’s comments, his comments are summarized below.

The wiring runs along the ceiling, out to the hallway and over to the wiring closet located on the central elevator core of the building. From the closet, the wire is run down to the wiring trough in the floor and back to the courtroom into the mixer, which is located at the court clerk’s desk. The building electrician advises that any new overhead speaker installations in Courtrooms B, C, D and E, should be wired in the same way.